

# NETTHINGS®

## NETTHINGS/EVINOX INTEGRATION

### MODBUS WIRING

#### NetThings Modbus Cable

- Fit the supplied cable to **PORT2** on the bottom face of the Energy Manager Controller.
- Route the cable to back box by removing the middle knock-out section, passing it between the cable support and the wall.
- The wiring connections to the Evinox controller are:



Modbus Signal	Colour
A+	Yellow
B-	Blue
GND	Green



#### Modbus Connections

- Connect the NetThings Controller to the HUI and the Room Controller.

Please see the appropriate Evinox documentation for further connections to the HIU.

